

REGIONAL WATER TESTING LAB, AMRITSAR

New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.

rwtlasr1@gmail.com

To,

SDE Water Supply and Sanitation Sub Division No.2 Gurdaspur At Kahnuwan
SDE Water Supply and Sanitation Sub Division No.2 Gurdaspur At Kahnuwan


No.: RWTLASR/2526/00228 Dated : 02/06/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 437 Dated: 29/05/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 29/05/2025. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Amritsar



Principal
S.S.R. World School
Vill. Kathana, P.O. Jagowal Bet
Gurdaspur (Pb.)



President
S. Surian Singh Riar Memorial
Educational Society
Vill. Kathana, P.O. Jagowal Bet, Gurdaspur (Pb.)

REGIONAL WATER TESTING LAB, AMRITSAR

New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

TEST REPORT						
Name & Address of Customer : SDE Water Supply and Sanitation Sub Division No.2 Gurdaspur At Kahnuwan SDE Water Supply and Sanitation Sub Division No.2 Gurdaspur At Kahnuwan			Customer Reference No.		No : 437 Dated : 29/05/2025	
			Sample Submitted by		S.Amarjit Singh	
			Date of Sample Receipt		29/05/2025	
			Analysis Starting Date		02/06/2025	
			Analysis completion Date		02/06/2025	
Discipline : Chemical Testing			Group: Water			
ULR No.:				Sample Type :		Water
Test Report No.:		RWTLASR/2526/00228		Date of Issue :		02/06/2025
Registration no.:		RWTLASR/REG2526/01729		Condition of Sample :		Sealed
Collection Point:		Private Submersible		Quantity/Type of Bottle:		500 ml / Transparent Glass Bottle
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		S.S.R World School Village Kathana,Gurdaspur (S/pump 350 ft),Sample Collected By Pritam Singh J.E Ph No.9872383564 / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Not Mentioned		District :		Gurdaspur
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Aluminium(Al)	BDL(0.010)	0.03	0.2	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
2	Lead	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
3	Selenium	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
4	Chromium(Cr)	BDL(0.005)	0.05	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
5	Mercury	BDL(0.0005)	0.001	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
6	Arsenic(As)	0.008	0.01	No relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
7	Cadmium(Cd)	BDL(0.001)	0.003	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
8	Nickel	BDL(0.005)	0.02	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
9	Iron(Fe)	BDL(0.005)	1	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
10	Copper(Cu)	0.019	0.05	1.5	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
11	Uranium	4.477	30	No Relaxation	µg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
12	Manganese(Mn)	0.036	0.1	0.3	mg/l	APHA (24th Ed. 2023) Method :3125 B By ICPMS
13	Zinc(Zn)	BDL(0.01)	5	15	mg/l	APHA (24th Ed. 2023) Method: 3125 B By ICPMS

Continue on next page...

Reviewed and Approved By

Pardeep

Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar

Surpreet Singh

President
S. Surian Singh Riar Memorial
Educational Society

Vill. Kathana, P.O. Jagowal Bet, Gurdaspur (Pb.)

P
Principal
S.S.R. World School
Vill. Kathana, P.O. Jagowal Bet
Gurdaspur (Pb.)

REGIONAL WATER TESTING LAB, AMRITSAR

New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.


rwtlasr1@gmail.com

14	Barium	0.106	0.7	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
----	--------	-------	-----	---------------	------	---

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: $25 \pm 5^{\circ}\text{C}$ and Humidity condition limit: $50 \pm 20\%$

Reviewed and Approved By



Mr. Pardeep kumar

Quality Manager

Authorized Signatory

For, Regional Water Testing Lab

Amritsar

----- End of the Test Report -----




Principal

S.S.R. World School

Vill. Kathana, P.O. Jagowal Bet

Gurdaspur (Pb.)



President

S. Surian Singh Riar Memorial

Educational Society

Vill. Kathana, P.O. Jagowal Bet, Gurdaspur (Pb.)